

SPECIFICATIONS

EXHAUST FAN



80 CFM/<0.3 Sones @ 0.10" SP. 110 CFM/0.7 Sones @ 0.10" SP. (Boost) 84 CFM @ 0.25 SP. (Boost)

Grill

White, polymeric grill secured in place with torsion springs; easily removed if necessary, dimensions - 147/16" x 147/16".

Blower Wheel

Balanced polymeric dual inlet blower wheel secured in place using a hex nut.

Motor

Enclosed 4 pole high efficiency, permanently split capacitor motor (PSC); life time lubrication, suitable for continuous operation. Motor bearings - ball. Rated 115/120 volts, 60 Hz.

Fan Housing

23 gauge galvanized steel housing. Overall dimensions: 127/8"x 123/4"x 97/8".

Humidity Sensor

Integrated humidity sensor automatically turns fan on until the desired humidity level is reached.

Duct Collar


6" round, zinc plated metal collar adapter. Gasketed, spring loaded aluminum backdraft damper.

Electrical Connections

1/2" electrical knockouts provided. Easy wiring access via either internal or external wiring compartment cover.

Single Pack Shipping Info

Box Dim: 20" x 157/8" x 113/8" UPC: 0-8316294128-2 Shipping Weight: 14.5 lbs.



Acceptable for use over tub or shower when installed in a GFCI protected branch circuit.



Unit Mounting

97/811

The housing will mount through drywall thickness up to 3/4", with a rough-in opening of 13" x 127/8". The housing will mount either between 16" or 24" on center joists, using the 2 supplied housing mounting brackets. The housing mounting brackets can be adapted for overhead mounting (hardware not provided). The unit is provided with an optionally installed ceiling flange to ensure proper building infiltration rates are maintained and that no air leaks occur between the fan housing and ceiling cutout.

EXPANDED PERFORMANCE											
							Sones	Fan Speed	Maximum		
	Static Pressure (inches of w.g.)						@ .1 SP	RPM	Power Watts	Amps	
	0	0.05	0.1	0.15	0.20	0.25*					
Air Flow - CFM	111	95	80	67	53	31/84	< 0.3	760	37.0	0.3	

^ Boost speed provides 84 CFM @ .25 Static Pressure, 0.7 sones										
PROJECT						ARCHITECT				
LOCATION						ENGINEER				
CONTRACTOR						SUBMITTED BY DATE				
CONTRACTOR						DATE DATE				
FAN MOD		IN	RPM	WATTS	AMPS	SONES	QTY	OPTIONAL EQUIPMENT		
NUMBER NUMB	R ULINI	W.G.	NF IVI	WAIIS	AIVIFO	SUNES	ų i i	& REMARKS		







U.S.: 820 Lincoln Avenue West Chester, Pennsylvania 19380-4466 Tel: (610) 692-7400 • 877-304-3785

Fax: (610) 696-8048

Canada:

Brampton, Ontario Tel: 905-456-2033

Specifications subject to change without notice Updated 11-23